

APPENDIX - VIII


PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 11257

Date : 09/04/2023

It is certified that an inspection team headed by Ramesh Gupta
Junior Engineer (Lab Head) (Name of Officers
with designation) from U.P. Jal Nigam Banda (Rural) (Name of
Department/Office) inspected the Tathagat Gyansthi
(Name & Address of
the School) on 09/04/2023 and found that the Tathagat Gyansthi
(Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of N/A.

Signature with Seal : 

Name :

Ramesh Gupta
Junior Engineer

Designation :


Division Office
U.P. Jal Nigam (Rural) Banda

To

Tathagat Gyansthi
Atarra - Banda. (U.P.)

(Name & Address of the Institution)

Manager
Tathagat Gyansthi
Senior Secondary School
Atarra (Banda)-210201


R.K. Verma
Principal
Tathagat Gyansthi
Senior Secondary School
Atarra (Banda)-210201

**ANALYSIS REPORT****DISTRICT LEVEL WATER ANALYSIS LABORATORY****U.P. JAL NIGAM, (Rural) BANDA-210001****E-mail Id :- wtlupjnbanda@gmail.com**

Report No. 11257	Date-
-------------------------	--------------

Office Name and Address		Executive Engineer, Divisional Office, U.P. Jal Nigam, (Rural) Banda			
District		Banda	Block		Naraini
Gram Panchayat		Atarra	Village		Atarra
Habitation			Location		Tathagat Gyansthli
Source		Tap Water	Sample Number		1
Quantity of sample		1 L	Date of sample collection		8/4/2023
Sample receiving date		8/4/2023	Name of sample collector		Kumkum Maurya
Name of sample depositor		Kulbhushan	Date of Initiation of Test		9/4/2023
Date of completion of Test					
S.No.	TESTED PARAMETERS	OBSERVED VALUES	SPECIFIED VALUES AS PER BIS		TEST METHOD
			Acceptable level (Limit)	Permissible Level (Limit) in the	
1	pH	7.38	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 2012 (Electrometric Method)
2	Turbidity (NTU)	1.27	1.00	5.00	IS 3025 (Part 10): 2012
3	TDS (mg/L)	155.9	500	2000	IS 3025 (Part 16): 2008
4	Total Hardness (mg/L)	228	200	600	IS 3025 (Part 21): 2009
5	Alkalinity (mg/L)	260	200	600	IS 3025 (Part 23): 2008
6	Chloride (mg/L)	60	250	1000	IS 3025 (Part 32): 2014
7	Nitrate (mg/L)*	-	45	45	APHA 23 rd edition 2017, Method 4500 No ₃ -B
8	Sulphate (mg/L)*	-	200	400	IS 3025 (Part 24): 2009 (Turbidity Method)
9	Residual Chlorine (mg/L)*	-	0.20	1.00	IS 3025 (Part 26): 1986
10	Iron (mg/L)*	-	0.30	No Relaxation	IS 3025 (Part 53):
11	Fluoride Electrode (mg/L)	-	1.00	1.50	IS 3025 (Part 60): 2008 (Electrochemical Probe Method)
12	Arsenic (mg/L)*	-	0.01	0.05	IS 3025 (Part 37)

NOTE-**Remarks- Safe Water**

- BDL refers to Belo Detection Limit.
- This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
- The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
- Sample will be stored up to 15 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.

Sign's
Chemist/ Lab Asst
Manager

Tathagat Gyansthli
Senior Secondary School
Atarra (Banda)-210201

Junior Engineer
Division Office

U.P. Jal Nigam (Rural) Banda

Assistant Engineer
Division Office
U.P. Jal Nigam (Rural) Banda

R. K. Verma
Principal
Tathagat Gyansthli
Senior Secondary School
Atarra (Banda)-210201

पत्रांक- मेमो /न0पा0प0(2022-23)/23 अतरा दिनांक- 23-03-2023

कार्यालय नगर पालिका परिषद, अतरा (बाँदा)

प्रमाण-पत्र

प्रमाणित किया जाता है कि मेरे द्वारा तथागत ज्ञानस्थली
अतरा (बाँदा) का निरीक्षण किया गया, निरीक्षण के समय
विद्यालय की सफाई व्यवस्था उत्कृष्ट पायी गयी।

23/03/23
अधिकांश अधिकारी
नगर पालिका परिषद, अतरा
नगर पालिका परिषद,
अतरा, (बाँदा)

—/वी-1 3 म॥
Manager
Tathagat Gyansthi
Senior Secondary School
Atarra (Banda)-210201

R. K. Verma
Principal
Tathagat Gyansthi
Senior Secondary School
Atarra (Banda)-210201